

Testing information				Result	Public Communication Plan
Test Date (dd-mm- yyy)	Outlet ID (optional)	Sample Type	Fixture Location Description	Exceeds Maximum Acceptable Concentration	
11-12-2022	211_1_104_CF	Flushed	Classroom Faucet (CF) in room 104, first floor, facility 211.	No	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement.  Retest fixture following replacement.
11.02.2025	AES DF Gym A	First Draw	Gym Drinking Fountain	No	-
11.02.2025	AES DF Gym B	Flushed	Gym Drinking Fountain	No	-
11.02.2025	AES KS Gym A	First Draw	Gym Kitchen Sink	Yes	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement.  Retest fixture following replacement.
11.02.2025	AES KS Gym B	Flushed	Gym Kitchen Sink	No	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement.  Retest fixture following replacement.
11.02.2025	AES DF RM 12	First Draw	Drinking fountain room 12	No	-
11.02.2025	AES DF RM 12	Flushed	Drinking fountain room 12	No	-
11.02.2025	AES KS STAFF	First Draw	Staff room kitchen sink	No	-
11.02.2025	AES KS STAFF	Flushed	Staff room kitchen sink	No	-
11.02.2025	AES BF ENT	First Draw	Bottle Filling entrance	No	-
11.02.2025	AES BF ENT	Flushed	Bottle Filling entrance	No	-
11.02.2025	AES DF RM 1	First Draw	Drinking fountain room 1	No	-
11.02.2025	AES DF RM 1	Flushed	Drinking fountain room 1	No	-

11.02.2025	AES KS 6/8	First Draw	Kitchen sink room 6/8	Yes	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement.
11.02.2025	AES KS 6/8	Flushed	Kitchen sink room 6/8	No	Retest fixture following replacement. Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement.
11.02.2025	AES KS RM 7	First Draw	Kitchen sink room 7	Yes	Retest fixture following replacement. Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement.
11.02.2025	AES KS RM 7	Flushed	Kitchen sink room 7	No	Retest fixture following replacement. Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement.
11.02.2025	AES DF RM 7	First Draw	Drinking fountain room 7	No	-
11.02.2025	AES DF RM 7	Flushed	Drinking fountain room 7	No	-
11.02.2025	AES KS DC	First Draw	Kitchen sink daycare	No	-
11.02.2025	AES KS DC	Flushed	Kitchen sink daycare	No	-
13.02.2025	QBES KS RM 118	First Draw	Kitchen sink room 118	No	-
13.02.2025	QBES KS RM 118	Flushed	Kitchen sink room 118	No	-
13.02.2025	QBES KS STAFF RM	First Draw	Kitchen sink staff room	No	-
13.02.2025	QBES KS STAFF RM	Flushed	Kitchen sink staff room	No	-
13.02.2025	QBES BF ENT	First Draw	Bottle filling entrance	No	-
13.02.2025	QBES BF ENT	Flushed	Bottle filling entrance	No	-
13.02.2025	QBES DF RM 134	First Draw	Drinking fountain room 134	No	-
13.02.2025	QBES DF RM 134	Flushed	Drinking fountain room 134	No	-
13.02.2025	QBES KS RM 140	First Draw	Kitchen sink room 140	No	-
13.02.2025	QBES KS RM 140	Flushed	Kitchen sink room 140	No	-

13.02.2025	QBES BF RM 216	First Draw	Bottle filling room 216	No	-
13.02.2025	QBES BF RM 216	Flushed	Bottle filling room 216	No	- Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement.
13.02.2025	QBES TKS RM 163	First Draw	Teacher kitchen sink room 163	Yes	Retest fixture following replacement. Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement.
13.02.2025	QBES TKS RM 163	Flushed	Teacher kitchen sink room 163	No	Retest fixture following replacement.
13.02.2025	QBES KS1 ROOM 163	First Draw	Kitchen sink foods room 163	No	-
13.02.2025	QBES KS1 ROOM 163	Flushed	Kitchen sink foods room 163	No	- Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement.
13.02.2025	QBES KS2 ROOM 163	First Draw	Kitchen sink foods room 163	Yes	Retest fixture following replacement. Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement.
13.02.2025	QBES KS2 ROOM 163	Flushed	Kitchen sink foods room 163	No	Retest fixture following replacement. Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement.
13.02.2025	QBES KS3 ROOM 163	First Draw	Kitchen sink foods room 163	Yes	Retest fixture following replacement. Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement.
13.02.2025	QBES KS3 ROOM 163	Flushed	Kitchen sink foods room 163	No	Retest fixture following replacement.

13.02.2025	QBES KS4 ROOM 163	First Draw	Kitchen sink foods room 163	Yes	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement.
13.02.2025	QBES KS4 ROOM 163	Flushed	Kitchen sink foods room 163	No	Retest fixture following replacement. Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement.
13.02.2025	QBES KS5 ROOM 163	First Draw	Kitchen sink foods room 163	Yes	Retest fixture following replacement. Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement.
13.02.2025	QBES KS5 ROOM 163	Flushed	Kitchen sink foods room 163	No	Retest fixture following replacement. Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement.
13.02.2025	QBES KS6 ROOM 163	First Draw	Kitchen sink foods room 163	Yes	Retest fixture following replacement. Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement.
13.02.2025	QBES KS6 ROOM 163	Flushed	Kitchen sink foods room 163	No	Retest fixture following replacement. Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement.
12.02.2025	EES DF GYM	First Draw	Drinking fountain gym	No	Retest fixture following replacement.
12.02.2025	EES DF GYM	Flushed	Drinking fountain gym	No	-
12.02.2025	EES KS GYM	First Draw	Kitchen sink gym	No	-
12.02.2025	EES KS GYM	Flushed	Kitchen sink gym	No	-

12.02.2025	EES DF ROOM 1	First Draw	Drinking fountain room 1	No	-
12.02.2025	EES DF ROOM 1	Flushed	Drinking fountain room 1	No	-
12.02.2025	EES KS SR	First Draw	Kitchen sink staff room	No	-
12.02.2025	EES KS SR	Flushed	Kitchen sink staff room	No	-
12.02.2025	EES BF ENT	First Draw	Bottle filling entrance	No	-
12.02.2025	EES BF ENT	Flushed	Bottle filling entrance	No	-
12.02.2025	EES DF ROOM 7	First Draw	Drinking fountain room 7	No	-
12.02.2025	EES DF ROOM 7	Flushed	Drinking fountain room 7	No	-
					Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement.
12.02.2025	EES KS ROOM 11/13	First Draw	Kitchen sink room 11/13	Yes	
					Retest fixture following replacement.
12.02.2025	EES KS ROOM 11/13	Flushed	Kitchen sink room 11/13	No	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement.
					Retest fixture following replacement.
12.02.2025	EES DF ROOM 14	First Draw	Drinking fountain room 14	No	-
12.02.2025	EES DF ROOM 14	Flushed	Drinking fountain room 14	No	-
					Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement.
13.02.2025	FBES T1 KS	First Draw	Teacherage 1 kitchen sink	Yes	
					Retest fixture following replacement.
					Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement.
13.02.2025	FBES T1 KS	Flushed	Teacherage 1 kitchen sink	No	
					Retest fixture following replacement.

13.02.2025	FBES T2 KS	First Draw	Teacherage 2 kitchen sink	Yes	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement.
13.02.2025	FBES T2 KS	Flushed	Teacherage 2 kitchen sink	No	Retest fixture following replacement. Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement.
13.02.2025	FBES SR KS	First Draw	Staff room kitchen sink	Yes	Retest fixture following replacement. Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement.
13.02.2025	FBES SR KS	Flushed	Staff room kitchen sink	No	Retest fixture following replacement. Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement.
13.02.2025	FBES DF	First Draw	School drinking fountain	Yes	Retest fixture following replacement. Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement.
13.02.2025	FBES DF	Flushed	School drinking fountain	No	Retest fixture following replacement. Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement.
13.02.2025	FBES KS	First Draw	School kitchen sink	No	Retest fixture following replacement.
13.02.2025	FBES KS	Flushed	School kitchen sink	No	-