

| Testing information | | | | Result | Public Communication Plan |
|-----------------------|-----------------------|-------------|---|--|---------------------------|
| Test Date (dd-mm-yyy) | Outlet ID (optional) | Sample Type | Fixture Location Description | Exceeds Maximum Acceptable Concentration | |
| 27-01-2026 | NBES room 2 | First Draw | Bottle filling station room 2 | No | N/A |
| 27-01-2026 | NBES room 2 | Flushed | Bottle filling station room 2 | No | N/A |
| 27-01-2026 | NBES hallway | First Draw | Bottle filling station hallway outside staff room | No | N/A |
| 27-01-2026 | NBES hallway | Flushed | Bottle filling station hallway outside staff room | No | N/A |
| 27-01-2026 | NBES staff room | First Draw | Staff room kitchen sink | No | N/A |
| 27-01-2026 | NBES staff room | Flushed | Staff room kitchen sink | No | N/A |
| 27-01-2026 | NBES room 8 | First Draw | Room 8 sink | No | N/A |
| 27-01-2026 | NBES room 8 | Flushed | Room 8 sink | No | N/A |
| 27-01-2026 | NBES gym | First Draw | Gym drinking fountain | No | N/A |
| 27-01-2026 | NBES gym | Flushed | Gym drinking fountain | No | N/A |
| 27-01-2026 | NBES kitchen room 21 | First Draw | Sink room 21 | No | N/A |
| 27-01-2026 | NBES kitchen room 21 | Flushed | Sink room 21 | No | N/A |
| 27-01-2026 | NBES kitchen room 41B | First Draw | Sink 41B | No | N/A |
| 27-01-2026 | NBES kitchen room 41B | Flushed | Sink 41B | No | N/A |
| 27-01-2026 | NBES room 9 | First Draw | Sink room 9 | No | N/A |
| 27-01-2026 | NBES room 9 | Flushed | Sink room 9 | No | N/A |
| 27-01-2026 | OES room 123 | First Draw | Sink room 123 | Yes | A |
| 27-01-2026 | OES room 123 | Flushed | Sink room 123 | No | A |
| 27-01-2026 | OES music room | First Draw | Drinking fountain music room | No | N/A |
| 27-01-2026 | OES music room | Flushed | Drinking fountain music room | No | N/A |
| 27-01-2026 | OES room 108 | First Draw | Sink room 108 | Yes | A |
| 27-01-2026 | OES room 108 | Flushed | Sink room 108 | No | A |
| 27-01-2026 | OES room 111 | First Draw | Sink 111 | No | N/A |
| 27-01-2026 | OES room 111 | Flushed | Sink 111 | No | N/A |
| 27-01-2026 | OES staff room | First Draw | Sink staff room | No | N/A |
| 27-01-2026 | OES staff room | Flushed | Sink staff room | No | N/A |

| | | | | | |
|------------|-------------------|------------|---|-----|-----|
| 27-01-2026 | OES room 104 | First Draw | Drinking fountain room 104 | No | N/A |
| 27-01-2026 | OES room 104 | Flushed | Drinking fountain room 104 | No | N/A |
| 27-01-2026 | OES Foyer | First Draw | Bottle Filling Station foyer area | No | N/A |
| 27-01-2026 | OES Foyer | Flushed | Bottle Filling Station foyer area | No | N/A |
| 27-01-2026 | OES room 105 | First Draw | Sink room 105 | No | N/A |
| 27-01-2026 | OES room 105 | Flushed | Sink room 105 | No | N/A |
| 27-01-2026 | OES room 106 | First Draw | Sink room 106 | Yes | A |
| 27-01-2026 | OES room 106 | Flushed | Sink room 106 | No | A |
| 27-01-2026 | OES room 107 | First Draw | Sink room 107 | Yes | A |
| 27-01-2026 | OES room 107 | Flushed | Sink room 107 | No | A |
| 27-01-2026 | OES MPR | First Draw | Sink in MPR | No | N/A |
| 27-01-2026 | OES MPR | Flushed | Sink in MPR | No | N/A |
| 27-01-2026 | OES Upstairs Hall | First Draw | Bottle filling station upstairs hallway | No | N/A |
| 27-01-2026 | OES Upstairs Hall | Flushed | Bottle filling station upstairs hallway | No | N/A |
| 27-01-2026 | SES room 106C | First Draw | Teacher sink room 106C | Yes | A |
| 27-01-2026 | SES room 106C | Flushed | Teacher sink room 106C | No | A |
| 27-01-2026 | SES room 106C #1 | First Draw | Student sink room 106C | Yes | A |
| 27-01-2026 | SES room 106C #1 | Flushed | Student sink room 106C | No | A |
| 27-01-2026 | SES room 106C #2 | First Draw | Student sink room 106C | No | N/A |
| 27-01-2026 | SES room 106C #2 | Flushed | Student sink room 106C | No | N/A |
| 27-01-2026 | SES room 106C #3 | First Draw | Student sink room 106C | Yes | A |
| 27-01-2026 | SES room 106C #3 | Flushed | Student sink room 106C | No | A |
| 27-01-2026 | SES room 106C #4 | First Draw | Student sink room 106C | No | N/A |
| 27-01-2026 | SES room 106C #4 | Flushed | Student sink room 106C | No | N/A |
| 27-01-2026 | SES room 106C #5 | First Draw | Student sink room 106C | No | N/A |
| 27-01-2026 | SES room 106C #5 | Flushed | Student sink room 106C | No | N/A |
| 27-01-2026 | SES room 106C #6 | First Draw | Student sink room 106C | Yes | A |
| 27-01-2026 | SES room 106C #6 | Flushed | Student sink room 106C | No | A |
| 27-01-2026 | SES room 106C #7 | First Draw | Student sink room 106C | No | N/A |
| 27-01-2026 | SES room 106C #7 | Flushed | Student sink room 106C | No | N/A |
| 27-01-2026 | SES room 114 | First Draw | Sink room 114 | No | N/A |
| 27-01-2026 | SES room 114 | Flushed | Sink room 114 | No | N/A |
| 27-01-2026 | SES room 116 | First Draw | Sink room 116 | No | N/A |

| | | | | | |
|------------|---------------------|---|---|-----|-----|
| 27-01-2026 | SES room 116 | Flushed | Sink room 116 | No | N/A |
| 27-01-2026 | SES room 117 | First Draw | Sink room 117 | No | N/A |
| 27-01-2026 | SES room 117 | Flushed | Sink room 117 | No | N/A |
| 27-01-2026 | SES room 119 | First Draw | Drinking fountain room 119 | No | N/A |
| 27-01-2026 | SES room 119 | Flushed | Drinking fountain room 119 | No | N/A |
| 27-01-2026 | SES room 132 | First Draw | Sink room 132 | No | N/A |
| 27-01-2026 | SES room 132 | Flushed | Sink room 132 | No | N/A |
| 27-01-2026 | SES foyer | First Draw | Bottle Filling Station foyer area | No | N/A |
| 27-01-2026 | SES foyer | Flushed | Bottle Filling Station foyer area | No | N/A |
| 27-01-2026 | SES MPR | First Draw | Sink MPR kitchen | Yes | A |
| 27-01-2026 | SES MPR | Flushed | Sink MPR kitchen | No | A |
| 27-01-2026 | SES music room | First Draw | Bottle filling station outside music room | No | N/A |
| 27-01-2026 | SES music room | Flushed | Bottle filling station outside music room | No | N/A |
| 27-01-2026 | SES room 124 | First Draw | Sink staff room | No | N/A |
| 27-01-2026 | SES room 124 | Flushed | Sink staff room | No | N/A |
| 27-01-2026 | SES room 218 | First Draw | Bottle filling station upstairs hallway | No | B |
| 27-01-2026 | SES room 218 | Flushed | Bottle filling station upstairs hallway | Yes | B |
| | A | Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. | | | |
| | B | Install a NSF 53/42 certified filter if the water point is essential and the source of lead is difficult to replace or could not be located and corrected. Retest after corrected work. | | | |