

**Water Sample Range Report**

Vancouver Island Health Authority

Central Island

**Facility Name:** ERRINGTON ELEMENTARY SCHOOL WWS  
**Facility Type:** DWQ  
**Date Range:** Jan 1 2012 to Dec 31 2012  
**Date Created:** Jan 18 2013

<u>Sampling Site</u>	<u>Date Collected</u>	<u>Total Coliform</u>	<u>E. Coli</u>	<u>Fecal Coliform</u>
<u>1390 Fairdowne Road, Errington, BC, WASHROOM @ Errington Elementary School, Dist. site, Monthly</u>	01/24/2012	L1	L1	
	02/21/2012	L1	L1	
	03/27/2012	L1	L1	
	04/24/2012	L1	L1	
	05/14/2012	L1	L1	
	06/19/2012	L1	L1	
	07/16/2012	L1	L1	
	08/22/2012	L1	L1	
	09/26/2012	L1	L1	
	10/24/2012	L1	L1	
	11/20/2012	L1	L1	
	12/11/2012	L1	L1	
<b>Total Positive:</b>		<b>0</b>	<b>0</b>	<b>0</b>
<u>Errington Elementary - AUDIT, Dist. site, No Regular Sampling</u>	09/18/2012	L1	L1	
	<b>Total Positive:</b>	<b>0</b>	<b>0</b>	<b>0</b>
<u>RAW - Pump House, ERRINGTON SCHOOL - RAW, Dist. site, No Regular Sampling</u>	09/18/2012	L1	L1	
	<b>Total Positive:</b>	<b>0</b>	<b>0</b>	<b>0</b>

Result Values:

E - estimated

L - less than

G - greater than

**Interpreting Sample Reports**

In VIHA, the results of drinking water sampling are reported using the following coding system:

L1 Less than 1 (no detectable bacteria) - Meaning: No bacteria present

OG Overgrown - Meaning: Too many background bacteria to give an accurate count

EST Estimated Count

and

A Sample not tested; Too long in transit

C Sample leaked/broken in transit

D Sample not tested; No collection date given

T Sample submitted unsatisfactory. Exceeded 30 hours holding time, please resample.

NS No sample received with requisition