



2021/22 REPORT FOR TESTING LEAD CONTENT IN DRINKING WATER OF SCHOOL FACILITIES

School District Information		Health Authority (HA) Information	
SD No.	69	Region	Region 2 Central Island
SD Name	Qualicum	Contact Name	Shawn Malakoe
SD Contact Name:	Chris Dempster	Contact Phone	250-755-6215
SD Contact Phone:	250-954-3030	Report Submitted to HA	Yes
Report Date	March 21 2022	Report Submission Date	March 31 2022

[Click here to access the School Master List for Facility Names and Facility Codes](#)

SCHOOL FACILITY INFORMATION				TEST INFORMATION					MITIGATION STRATEGY & PUBLIC HEALTH	
School District Number	Ministry Facility Code	School Facility Name	Year Built	Date of Test (mm/yyyy)	Total Samples	Water Fixture Type	Room Location	Lead Level Result (mg/L)	Exceed Maximum Acceptable Concentrations	Mitigation Strategy Description
69	6969021	Ecole Ballenas Secondary School	1977	Mar-22	1	Sink	Library sink	0.021	Yes	Run water for 30 second sign to be put up
69	6969021	Ecole Ballenas Secondary School	1977	Mar-22	1	Sink	Library sink	0.003	No	Run water for 30 second sign to be put up
69	6969021	Ecole Ballenas Secondary School	1977	Mar-22	1	Sink	Room 605	0.022	Yes	Remove from site
69	6969021	Ecole Ballenas Secondary School	1977	Mar-22	1	Sink	Room 605	0.009	Yes	Remove from site
69	6969021	Ecole Ballenas Secondary School	1977	Mar-22	1	Sink	Room 700	0.001	No	
69	6969021	Ecole Ballenas Secondary School	1977	Mar-22	1	Sink	Room 700	0.000	No	
69	6969021	Ecole Ballenas Secondary School	1977	Mar-22	1	Sink	Room 700 2nd sink	0.008	Yes	Run water for 30 second sign to be put up
69	6969021	Ecole Ballenas Secondary School	1977	Mar-22	1	Sink	Room 700 2nd sink	0.003	No	Run water for 30 second sign to be put up
69	6969021	Ecole Ballenas Secondary School	1977	Mar-22	1	Sink	Room 701 Near hallway	0.003	No	
69	6969021	Ecole Ballenas Secondary School	1977	Mar-22	1	Sink	Room 701 Near hallway	0.001	No	
69	6969021	Ecole Ballenas Secondary School	1977	Mar-22	1	Sink	Room 701 Back of room	0.004	No	
69	6969021	Ecole Ballenas Secondary School	1977	Mar-22	1	Sink	Room 701 Back of room	0.001	No	
69	6969021	Ecole Ballenas Secondary School	1977	Mar-22	1	Sink	Room 702	0.003	No	
69	6969021	Ecole Ballenas Secondary School	1977	Mar-22	1	Sink	Room 702	0.001	No	
69	6969021	Ecole Ballenas Secondary School	1977	Mar-22	1	Sink	Room 801	0.008	Yes	Remove from site
69	6969021	Ecole Ballenas Secondary School	1977	Mar-22	1	Sink	Room 801	0.005	Yes	Remove from site
69	6969021	Ecole Ballenas Secondary School	1977	Mar-22	1	Sink	Room 804	0.020	Yes	



SCHOOL FACILITY INFORMATION				TEST INFORMATION						MITIGATION STRATEGY & PUBLI
School District Number	Ministry Facility Code	School Facility Name	Year Built	Date of Test (mm/yyyy)	Total Samples	Water Fixture Type	Room Location	Lead Level Result (mg/L)	Exceed Maximum Acceptable Concentrations	Mitigation Strategy Description
69	6969021	Ecole Ballenas Secondary School	1977	Mar-22	1	Sink	Room 804	0.001	No	
69	6969025	Springwood Elementary School Annex	1964	Mar-22	1	Sink	Room 6	0.030	Yes	Run water for 30 second sign to be put up
69	6969025	Springwood Elementary School Annex	1964	Mar-22	1	Sink	Room 6	0.001	No	Run water for 30 second sign to be put up
69	6969025	Springwood Elementary School Annex	1964	Mar-22	1	Sink	Room 7	0.004	No	
69	6969025	Springwood Elementary School Annex	1964	Mar-22	1	Sink	Room 7	0.000	No	
69	6969025	Springwood Elementary School Annex	1964	Mar-22	1	Sink	Room 14	0.035	Yes	Run water for 30 second sign to be put up
69	6969025	Springwood Elementary School Annex	1964	Mar-22	1	Sink	Room 14	0.003	No	Run water for 30 second sign to be put up
69	6969094	Collaborative Education	1964		1	Sink	Room 1 SOS	0.008	Yes	Run water for 30 second sign to be put up
69	6969094	Collaborative Education	1964		1	Sink	Room 1 SOS	0.001	No	Run water for 30 second sign to be put up
69	6969094	Collaborative Education	1964		1	Sink	Room 2 Discovery	0.006	Yes	Run water for 30 second sign to be put up
69	6969094	Collaborative Education	1964		1	Sink	Room 2 Discovery	0.001	No	Run water for 30 second sign to be put up
69	6969094	Collaborative Education	1964		1	Sink	Room 3 Munchkinland	0.002	No	
69	6969094	Collaborative Education	1964		1	Sink	Room 3 Munchkinland	0.001	No	
69	6969094	Collaborative Education	1964		1	Sink	Room 4 Munchkinland	0.007	Yes	Run water for 30 second sign to be put up
69	6969094	Collaborative Education	1964		1	Sink	Room 4 Munchkinland	0.001	No	Run water for 30 second sign to be put up
69	6969094	Collaborative Education	1964		1	Sink	Room 6 daycare	0.002	No	
69	6969094	Collaborative Education	1964		1	Sink	Room 6 daycare	0.001	No	
69	6969094	Collaborative Education	1964		1	Sink	Room 7 doctors office	0.012	Yes	Run water for 30 second sign to be put up
69	6969094	Collaborative Education	1964		1	Sink	Room 7 doctors office	0.002	No	Run water for 30 second sign to be put up
69	6969094	Collaborative Education	1964		1	Sink	Room 8	0.007	Yes	Run water for 30 second sign to be put up
69	6969094	Collaborative Education	1964		1	Sink	Room 8	0.001	No	Run water for 30 second sign to be put up
69	6969094	Collaborative Education	1964		1	Sink	Room 9 VIDA	0.007	Yes	Run water for 30 second sign to be put up
69	6969094	Collaborative Education	1964		1	Sink	Room 9 VIDA	0.001	No	Run water for 30 second sign to be put up
69	6969094	Collaborative Education	1964		1	Sink	Room 11	0.002	No	
69	6969094	Collaborative Education	1964		1	Sink	Room 11	0.001	No	
69	6969094	Collaborative Education	1964		1	Sink	Room 12	0.013	Yes	Run water for 30 second sign to be put up
69	6969094	Collaborative Education	1964		1	Sink	Room 12	0.001	No	Run water for 30 second sign to be put up