

School District Information		Health Authority (HA) Information	
SD No	69	Region	Region 2 Central Island
SD Name	Qualicum	Contact Name	Claire Webb
SD Contact Name	Phil Munro	Contact Phone	250-947-8222 (extension 39185)
SD Contact Phone	250-954-3030	Report Submitted to HA	Yes
Report Date	28-Feb-24	Report Submission Date	28-Feb-24

School Sampling Information						Proportion of fixtures sampled this year	Number of fixtures remaining to be sampled in this 3-year cycle.
Ministry Asset Number	Facility Name	Year Facility Built	Total Number of Fixtures Identified	Number of Fixtures Sampled in this Report	Number of Fixtures Sampled in Last 3 years	Policy requires 33% fixtures to be sampled each year	
106386	Ballenas Secondary School	1977	12	12	0	1	0
106392	Kwailicum Secondary School	1982	6	6	0	1	0
106383	Bowser Elementary School	1983	5	5	0	1	0
106389	Winchelsea Elementary	1981	5	5	0	1	0
106354	Qualicum Beach Elementary / Commons	1946	9	9	0	1	0
106346	Parksville Elementary	1910	19	19	0	1	0
120752	Springwood Elementary School	1996	16	1	15	1	0

School Identifier	Testing information						Result		Mitigation Strategy Selected	Public Communication Plan
	Ministry Asset Number	Test Date (dd-mm-yyy)	Time of test (24hr clock)	Outlet ID (optional)	Sample Type	Fixture Type	Fixture Location Description	Lead Result (mg/L)		
123456	11-12-2022	07:45:00	211_1_104_CF	Flushed	CF	Classroom Faucet (CF) in room 104, first floor, facility 211.	0.0043	No	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.
106386	16-02-2024	06:24:00	BSS 4A	First Draw	DW	Boys change room	0.0027	No	NA	
106386	16-02-2024	06:26:00	BSS 4B	Flushed	DW	Boys change room	0.00045	No	NA	
106386	16-02-2024	06:28:00	BSS 5A	First Draw	DW	Girls change room	0.0073	Yes	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.
106386	16-02-2024	06:30:00	BSS 5B	Flushed	DW	Girls change room	0.00086	No	NA	
106386	15-02-2024	07:10:00	BSS 6A	First Draw	DW	Work out room	0.0033	No	NA	
106386	15-02-2024	07:12:00	BSS 6B	Flushed	DW	Work out room	0.00053	No	NA	
106386	15-02-2024	06:51:00	BSS 1A	First Draw	DW	300 wing outside custodial room	0.0049	No	NA	
106386	15-02-2024	06:53:00	BSS 1B	Flushed	DW	300 wing outside custodial room	0.0018	No	NA	
106386	15-02-2024	06:47:00	BSS 2A	First Draw	BS	Outside library	0.00062	No	NA	
106386	15-02-2024	06:49:00	BSS 2B	Flushed	BS	Outside library	0.00077	No	NA	
106386	15-02-2024	07:05:00	BSS 3A	First Draw	DW	Next to rear exit doors near wood shop	0.0071	Yes	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.
106386	15-02-2024	07:07:00	BSS 3B	Flushed	DW	Next to rear exit doors near wood shop	0.0022	No	NA	
106386	15-02-2024	06:44:00	BSS 7A	First Draw	KC	Sink staff room	0.0027	No	NA	
106386	15-02-2024	06:46:00	BSS 7B	Flushed	KC	Sink staff room	0.00079	No	NA	
106386	15-02-2024	06:58:00	BSS 8A	First Draw	KC	Room 700 sink (hub) coffee kitchen	0.00081	No	NA	
106386	15-02-2024	07:00:00	BSS 8B	Flushed	KC	Room 700 sink (hub) coffee kitchen	0.00082	No	NA	
106386	15-02-2024	07:17:00	BSS 9A	First Draw	KC	Room 803 kitchen	0.0054	Yes	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.
106386	15-02-2024	07:19:00	BSS 9B	Flushed	KC	Room 803 kitchen	0.00087	No	NA	
106386	15-02-2024	06:54:00	BSS 10A	First Draw	KC	400 block kitchen sink	0.0016	No	NA	
106386	15-02-2024	06:56:00	BSS 10B	Flushed	KC	400 block kitchen sink	0.00091	No	NA	
106386	15-02-2024	07:20:00	BSS 11A	First Draw	KC	Room 804 kitchen sink	0.033	Yes	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.
106386	15-02-2024	07:22:00	BSS 11B	Flushed	KC	Room 804 kitchen sink	0.0016	No	NA	

106386	16-02-2024	06:20:00	BSS 12A	First Draw	BS	Backing on to theatre	0.00084	No	NA
106386	16-02-2024	06:22:00	BSS 12B	Flushed	BS	Backing on to theatre	0.00077	No	NA
106392	16-02-2024	07:21:00	KSS 1A	First Draw	BS	Gym area	0.0009	No	NA
106392	16-02-2024	07:23:00	KSS 1B	Flushed	BS	Gym area	0.00089	No	NA
106392	16-02-2024	07:13:00	KSS 2A	First Draw	BS	Lower floor outside CEAP washrooms	0.0012	No	NA
106392	16-02-2024	07:15:00	KSS 2B	Flushed	BS	Lower floor outside CEAP washrooms	0.00099	No	NA
106392	16-02-2024	07:08:00	KSS 3A	First Draw	DW	Shops hallway	0.011	Yes	2A Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.
106392	16-02-2024	07:10:00	KSS 3B	Flushed	DW	Shops hallway	0.0026	No	NA
106392	16-02-2024	06:59:00	KSS 4A	First Draw	BS	Outside science rooms in hallway	0.0015	No	NA
106392	16-02-2024	07:01:00	KSS 4B	Flushed	BS	Outside science rooms in hallway	0.0011	No	NA
106392	16-02-2024	07:17:00	KSS 5A	First Draw	KC	Room 154 sink small kitchen	0.0061	Yes	2A Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.
106392	16-02-2024	07:19:00	KSS 5B	Flushed	KC	Room 154 sink small kitchen	0.0012	No	NA
106392	16-02-2024	07:03:00	KSS 6A	First Draw	KC	Room 217 kitchen sink	0.00087	No	NA
106392	16-02-2024	07:05:00	KSS 6B	Flushed	KC	Room 217 kitchen sink	0.0012	No	NA
120752	16-02-2024	06:34:00	SES 1A	First Draw	KC	Room 107B kitchen sink	0.00068	No	NA
120752	16-02-2024	06:34:00	SES 1B	Flushed	KC	Room 107B kitchen sink	0.00041	No	NA
106354	16-02-2024	07:36:00	QBC 1A	First Draw	DW	Main entrance outside boys washroom	0.0014	No	NA
106354	16-02-2024	07:38:00	QBC 1B	Flushed	DW	Main entrance outside boys washroom	0.00093	No	NA
106354	16-02-2024	07:42:00	QBC 2A	First Draw	KC	Room 15	0.0036	No	NA
106354	16-02-2024	07:44:00	QBC 2B	Flushed	KC	Room 15	0.0013	No	NA
106354	16-02-2024	08:13:00	QBC 3A	First Draw	DW	Hallway between gym and CEAP washrooms	0.008	Yes	2A Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.
106354	16-02-2024	08:15:00	QBC 3B	Flushed	DW	Hallway between gym and CEAP washrooms	0.0006	No	NA
106354	16-02-2024	08:06:00	QBC 4A	First Draw	DW	Sports medicine room across from room 3B	0.00079	No	NA
106354	16-02-2024	08:08:00	QBC 4B	Flushed	DW	Sports medicine room across from room 3B	0.00042	No	NA
106354	16-02-2024	07:56:00	QBC 5A	First Draw	KC	Sink kitchen SOS	0.0051	Yes	2A Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.
106354	16-02-2024	07:58:00	QBC 5B	Flushed	KC	Sink kitchen SOS	0.00047	No	NA
106354	16-02-2024	N/A	QBC 6A	First Draw	KC	Studio Kitchen sink	0.00098	No	NA
106354	16-02-2024	N/A	QBC 6B	Flushed	KC	Studio Kitchen sink	0.00042	No	NA
106354	16-02-2024	N/A	QBC 7A	First Draw	CF	Room 5 sink	0.00039	No	NA
106354	16-02-2024	N/A	QBC 7B	Flushed	CF	Room 5 sink	0.00029	No	NA
106354	16-02-2024	N/A	QBC 8A	First Draw	CF	Sink Room 19 VICDS	0.014	Yes	2A Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.
106354	16-02-2024	N/A	QBC 8B	Flushed	CF	Sink Room 19 VICDS	0.0012	No	NA
106354	16-02-2024	07:48:00	QBC 9A	First Draw	DW	Room 14A	0.0045	No	NA
106354	16-02-2024	07:50:00	QBC 9B	Flushed	DW	Room 14A	0.0013	No	NA
106346	16-02-2024	06:49:00	CSC 1A	First Draw	DW	Room 1 daycare	0.00094	No	NA
106346	16-02-2024	06:51:00	CSC 1B	Flushed	DW	Room 1 daycare	0.0002	No	NA
106346	16-02-2024	06:55:00	CSC 2A	First Draw	DW	Room 2 daycare	0.00089	No	NA
106346	16-02-2024	06:57:00	CSC 2B	Flushed	DW	Room 2 daycare	0.0002	No	NA
106346	16-02-2024	07:39:00	CSC 3A	First Draw	DW	Room 19	0.0011	No	NA
106346	16-02-2024	07:41:00	CSC 3B	Flushed	DW	Room 19	0.0004	No	NA
106346	16-02-2024	07:36:00	CSC 4A	First Draw	DW	Room 20	0.00013	No	NA
106346	16-02-2024	07:38:00	CSC 4B	Flushed	DW	Room 20	0.00034	No	NA
106346	16-02-2024	07:43:00	CSC 5A	First Draw	DW	Main entrance outside boys washroom	0.0039	No	NA
106346	16-02-2024	07:45:00	CSC 5B	Flushed	DW	Main entrance outside boys washroom	0.00038	No	NA
106346	16-02-2024	06:45:00	CSC 6A	First Draw	CF	Sink old staffroom now daycare	0.0013	No	NA
106346	16-02-2024	06:47:00	CSC 6B	Flushed	CF	Sink old staffroom now daycare	0.0002	No	NA
106346	16-02-2024	07:46:00	CSC 7A	First Draw	KC	Sink kitchen off main entrance	0.021	Yes	2A Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.
106346	16-02-2024	07:48:00	CSC 7B	Flushed	KC	Sink kitchen off main entrance	0.0007	No	NA
106346	16-02-2024	06:53:00	CSC 8A	First Draw	KC	Sink kitchen between rooms 1 & 2 daycare	0.0018	No	NA
106346	16-02-2024	06:55:00	CSC 8B	Flushed	KC	Sink kitchen between rooms 1 & 2 daycare	0.00023	No	NA
106346	16-02-2024	07:00:00	CSC 9A	First Draw	KC	Sink kitchen in old library	0.0013	No	NA
106346	16-02-2024	07:02:00	CSC 9B	Flushed	KC	Sink kitchen in old library	0.0002	No	NA

106346	16-02-2024	07:03:00	CSC 10A	First Draw	CF	Sink classroom 6	0.0052	Yes	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement.
										Retest fixture following replacement.
106346	16-02-2024	07:05:00	CSC 10B	Flushed	CF	Sink classroom 6	0.00038	No	NA	
106346	16-02-2024	07:06:00	CSC 11A	First Draw	CF	Sink classroom 7	0.0019	No	NA	
106346	16-02-2024	07:08:00	CSC 11B	Flushed	CF	Sink classroom 7	0.00039	No	NA	
106346	16-02-2024	07:13:00	CSC 12A	First Draw	CF	Sink classroom 8	0.00059	No	NA	
106346	16-02-2024	07:15:00	CSC 12B	Flushed	CF	Sink classroom 8	0.0002	No	NA	
106346	16-02-2024	07:10:00	CSC 13A	First Draw	CF	Sink classroom 9	0.0012	No	NA	
106346	16-02-2024	07:12:00	CSC 13B	Flushed	CF	Sink classroom 9	0.0002	No	NA	
106346	16-02-2024	07:16:00	CSC 14A	First Draw	CF	Sink classroom 10	0.0014	No	NA	
106346	16-02-2024	07:18:00	CSC 14B	Flushed	CF	Sink classroom 10	0.0002	No	NA	
106346	16-02-2024	07:19:00	CSC 15A	First Draw	CF	Sink classroom 11	0.00047	No	NA	
106346	16-02-2024	07:21:00	CSC 15B	Flushed	CF	Sink classroom 11	0.0002	No	NA	
106346	16-02-2024	07:22:00	CSC 16A	First Draw	CF	Sink classroom 12	0.00035	No	NA	
106346	16-02-2024	07:24:00	CSC 16B	Flushed	CF	Sink classroom 12	0.0002	No	NA	
106346	16-02-2024	07:26:00	CSC 17A	First Draw	CF	Sink classroom 13	0.00063	No	NA	
106346	16-02-2024	07:28:00	CSC 17B	Flushed	CF	Sink classroom 13	0.0002	No	NA	
106346	16-02-2024	07:29:00	CSC 18A	First Draw	CF	Sink classroom 14	0.0013	No	NA	
106346	16-02-2024	07:31:00	CSC 18B	Flushed	CF	Sink classroom 14	0.0002	No	NA	
106346	16-02-2024	07:32:00	CSC 19A	First Draw	CF	Sink classroom 15	0.0041	No	NA	
106346	16-02-2024	07:34:00	CSC 19B	Flushed	CF	Sink classroom 15	0.0002	No	NA	
106389	15-02-2024	06:24:00	WW/PASS 1A	First Draw	BS	Between room 12 and washrooms	0.00065	No	NA	
106389	15-02-2024	06:26:00	WW/PASS 1B	Flushed	BS	Between room 12 and washrooms	0.00075	No	NA	
106389	15-02-2024	06:19:00	WW/PASS 2A	First Draw	DW	Hallway gym washrooms	0.0062	Yes	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement.
										Retest fixture following replacement.
106389	15-02-2024	06:21:00	WW/PASS 2B	Flushed	DW	Hallway gym washrooms	0.0014	No	NA	
106389	15-02-2024	06:34:00	WW/PASS 3A	First Draw	DW	Hallway outside library	0.0052	Yes	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement.
										Retest fixture following replacement.
106389	15-02-2024	06:36:00	WW/PASS 3B	Flushed	DW	Hallway outside library	0.0025	No	NA	
106389	15-02-2024	06:27:00	WW/PASS 4A	First Draw	KC	Sink kitchen foods room	0.0028	No	NA	
106389	15-02-2024	06:29:00	WW/PASS 4B	Flushed	KC	Sink kitchen foods room	0.000082	No	NA	
106389	15-02-2024	06:31:00	WW/PASS 5A	First Draw	KC	Sink kitchen between rooms 14 and 15	0.0021	No	NA	
106389	15-02-2024	06:33:00	WW/PASS 5B	Flushed	KC	Sink kitchen between rooms 14 and 15	0.00064	No	NA	
106383	15-02-2024	07:08:00	BES 1A	First Draw	BS	Main entrance	0.00041	No	NA	
106383	15-02-2024	07:10:00	BES 1B	Flushed	BS	Main entrance	0.00037	No	NA	
106383	15-02-2024	07:18:00	BES 2A	First Draw	DW	Outside staff washroom	0.0017	No	NA	
106383	15-02-2024	07:21:00	BES 2B	Flushed	DW	Outside staff washroom	0.00082	No	NA	
106383	15-02-2024	07:30:00	BES 3A	First Draw	KC	Sink staff room	0.00041	No	NA	
106383	15-02-2024	07:32:00	BES 3B	Flushed	KC	Sink staff room	0.00031	No	NA	
106383	15-02-2024	07:25:00	BES 4A	First Draw	KC	Sink MPR Kitchen	0.0011	No	NA	
106383	15-02-2024	07:22:00	BES 4B	Flushed	KC	Sink MPR Kitchen	0.0003	No	NA	
106383	15-02-2024	07:13:00	BES 5A	First Draw	DW	Room 1 kindergarden	0.011	Yes	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement.
										Retest fixture following replacement.
106383	15-02-2024	07:15:00	BES 5B	Flushed	DW	Room 1 kindergarden	0.0027	No	NA	